

GOVERNMENT OF WEST BENGAL
OFFICE OF THE DIVISIONAL FIRE OFFICER
WEST BENGAL FIRE & EMERGENCY SERVICES
S.F. Road, P.O. - Siliguri, P.S. - Siliguri Bazar, Pin -
734005

Memo No. IND/WB/FES/20192020/86017

DATE: 29/02/2020

From :

The Divisional Fire Officer
Fire Prevention Wing,
West Bengal Fire & Emergency Services.

To :

Wood Ridge International School prop Vinod Kumar Rai
New Chanta Matigara Darjeeling
Matigara F.S., Matigara,
Darjeeling - 734009 .

Sub :Renewal of Fire Safety Certificate for the occupancy of an existing construction of G + 2 storied building under group Educational at the premises no.- New Chanta Matigara Darjeeling, Matigara, Darjeeling - 734009

This is in reference to your Application No. IND/WB/FES/20192020/86017, dated 29/02/2020, regarding the Renewal of Fire Safety Certificate for the occupancy of an existing construction of G + 2 storied building under group Educational at the premises no.- New Chanta Matigara Darjeeling, Matigara, Darjeeling - 734009.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Renewal of Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

1 Subject to fulfillment following conditions

- 1) Good housekeeping to be maintained both inside as well as outside the building
- 2) Exit Numbers as well as directional signs of escape routes to be prominently displayed

- 3) Fire Notice for evacuation and fire fighting to be prepared to display at all vulnerable places in the building
- 4) The occupants, employees and security staff to be made well-conversant about the installed fire safety and protection measures for their use in exigencies
- 5) Mock practice and fire evacuation drills to be organized for the regular periodical performance in accordance to the National Building Code - Part IV.
- 6) Electrical wiring of the afore said building should be checked and maintenance to be done by an licensed electrician.
- 7) Trained Firemen and Fire Officers in the form of prescribed crew to be maintained for round the clock safety of the establishment.
- 8) Mock practice and fire evacuation drills to be organized for the regular periodical performance in accordance to the National Building Code - Part IV.
- 9) All Exit & Entrance should be free from obstruction.

This certificate is valid for 3 year u/r 18 of WBFS (Fire Prevention and Safety) Rules,2003 and renewable to after 3 year from the date of issue failing which this shall be revoked automatically.

Divisional Fire Officer
West Bengal Fire & Emergency Services

Signature valid
Digitally signed by DEWAN
LEPCHA
Date: 2020.02.29 07:51:57 IST